

OFFICE USE ONLY  
 Log No. 44394  
 Permit No. \_\_\_\_\_  
 Basin. 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24920

1. OWNER DECARLO CUSTOM HOMES ADDRESS AT WELL LOCATION 262 WATER CANYON  
 MAILING ADDRESS MINDEN, NV GENOA

2. LOCATION NE 1/4 SW 1/4 Sec. 10 T. 13 N. R. 20 E DOUGLAS County  
 PERMIT NO. 17-122-02 GENOA Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	2
grey Sand		2	12	10
Silt w/ gravel		12	42	30
Sandy clay w/ <sup>some</sup> gravel		42	51	9
DG w/ sandy clay		51	75	24
Sandy clay		75	81	6
DG w/ short sh. <sup>3/4" sh.</sup> clay		81	134	53
Sandy clay		134	140	6

8. WELL CONSTRUCTION  
 Depth Drilled 0 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Fect)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Factory Slotted  
 Size perforation 3x 3/32  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 140 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow 2 G.P.M. 3 P.S.I.  
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD Contractor  
FALLON, NV 89406  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535  
 Signed Joseph W. Phinney  
 By driller performing actual drilling on site or contractor  
 Date 4-11-94

Date started 4-8, 1994  
 Date completed 4-11, 1994

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25+</u>		<u>2</u>