WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44364
Permit No.
Basin 162

NOTICE OF INTENT NO. 13014

1. OWNER JAMIE PENA
MAILING ADDRESS HCR 77 BOX 44324
PAHRUMP NV. 89041

ADDRESS AT WELL LOCATION RANCHO DEL SOL
LOT 21 UNIT 2 Pahrump,
NEVADA 89041

2. LOCATION S-E ¼ N-E ¼ Sec. 33 T 19 S N/S R 53E E NYE County
PERMIT NO. (Issued by Water Resources) 29-842-21 (Parcel No.) RANCHO DEL-SOL (Subdivision Name)

3. WORK PERFORMED
XX New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
XX Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
XX Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY SOIL		0	8	8
BROWN CLAY		8	65	57
GRAVEL	X	57	62	5
GREY CLAY	X	62	102	40
SAND STONE OR	X			
CALICHIE	X	102	108	6
GREY CLAY	X	108	140	32

RECEIVED
APR 25 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started ....., 19....
Date completed ....., 19....

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	30	½ Hour

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
X 12 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:
Type perforation FACTORY
Size perforation 3 X 16 X 4
From 140 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: XX Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout XX Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 140' feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow ..... G.P.M. ..... P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LARRY'S WATEER WELL SERVICE (Contractor)
Address P.O. BOX 3392 (Contractor)
PAHRUMP, NEVADA 89041

Nevada contractor's license number issued by the State Contractor's Board 0035901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed Larry H Jenkins (By driller performing actual drilling on site or contractor)
Date 4-18-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627