WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44365
Permit No.
Basin 162

NOTICE OF INTENT NO. 13016

1. OWNER JOHN DELAMETER
MAILING ADDRESS PO Box 1659
Idaho Springs Co- 80452

ADDRESS AT WELL LOCATION LOT # 20
BLOSSER RANCH ROAD
PAHRUMP, NEVADA 89041

2. LOCATION S-E ¼ N-E ¼ Sec. 33 T 19 S N/S R 53 E E NYE County

PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY SOIL		0	10	10
BROWN CLAY		10	62	52
GRAVEL	X	62	67	5
CALICHIE	X	67	95	28
GREY CLAY	X	70	105	35
CALICHIE	X	105	112	7
GREY CLAY	X	112	140	28

RECEIVED
APR 25 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started , 19
Date completed , 19

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	25	½ HOUR

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:
Type perforation FACTORY
Size perforation 3 X 16 X 4
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50' feet to 140' feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LARRY'S WATER WELL SERVICE (Contractor)
Address P.O. BOX 3392 (Contractor)
PAHRUMP, NEVADA 89041

Nevada contractor's license number issued by the State Contractor's Board 0035901

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916

Signed Larry H. [illegible] (By driller performing actual drilling on site or contractor)
Date 4-18-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627