WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44389
Permit No.
Basin 049

NOTICE OF INTENT NO. 22894

1. OWNER Ron Giustin
MAILING ADDRESS P.O. Box 5281
Elko NV 89802

ADDRESS AT WELL LOCATION Second Lot in On west side of Wildrice Dr

2. LOCATION NE ¼ SW ¼ Sec. 34 T. 35 N/S R. 55 E. Elko County

PERMIT NO. ____ Issued by Water Resources | 06-10B-17-2 Parcel No. | Kittridge Cyn Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sod soil		0	1	1
Gravel	x	1	24	23
Cemented sandstone		24	240	216
Lose sandstone	x	240	250	10

'94 MAY 23 P1:49
RECEIVED
STATE ENGINEERS OFF

Date started 4-27, 1994
Date completed 4-5-9, 1994

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
55-60		5.5

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	60 Feet
8 7/8 Inches	60 Feet	250 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	188	+2	250

Perforations:
Type perforation slots
Size perforation 3/16 x 3"
From 230 feet to 250 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 250 feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Gold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Co
Contractor
Address P.O. Box 525
Contractor
Elko NV 89803

Nevada contractor's license number issued by the State Contractor's Board 31904

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shoul e Fertig h
By driller performing actual drilling on site or contractor

Date 5-17-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627