

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12071

1. OWNER BARRICK GOLDSTRIKE MINE ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. BOX 79 _____
ELKO, NEVADA 89801 _____
 2. LOCATION NW 1/4 SE 1/4 Sec. 19 T. 36 N. R. 50 E. EUREKA County
 PERMIT NO. 55140 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & ROCK		0	45	45
SAND, GRAVEL & CLAY		45	240	195
RED CLAY, SAND & ROCK		240	301	61
GRAY STICKY CLAY		301	312	11
RED CLAY, SAND & ROCK		312	402	90
RED CLAY & SAND		402	425	23
STICKY CLAY		425	435	10
CLAY & GRAVEL		435	460	25
STICKY CLAY		460	491	31
BLK. ROCK		491	566	77
CLAY & ROCK		566	580	14
STICKY CLAY & ROCK		580	586	6
CLAY GRAVEL & ROCK		586	622	36
GRAVEL & CLAY		622	689	67
RED/GRAY CLAY		689	727	38
RED CLAY W/ROCK		727	763	36
GRAY/WHT. CLAY		763	778	15
GRAVEL/SH. CLAY		778	801	23
GRAVEL & CLAY		801	833	32
CLAY & GRAVEL		833	844	11
BLK. ROCK & GRAVEL		844	881	37
RED CLAY		881	889	8
GRAY ROCK		889	922	33
BLACK CLAY		922	940	18
GR/BLK ROCK W/CLAY		940	1046	106
GR. CLAY & SAND		1046	1073	27
GRAY CLAY		1073	1110	37

8. WELL CONSTRUCTION
 Depth Drilled 1110 Feet Depth Cased 1105 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
36 Inches 0 Feet 100 Feet
17 1/2 Inches 100 Feet 1110 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24	84.5	3/8	0	38
12	33.38	1/4	0	1105

Perforations:
 Type perforation MILL SLOT
 Size perforation 1/4"
 From 120 feet to 160 feet
 From 200 feet to 240 feet
 From 360 feet to 400 feet
 From 500 feet to 1100 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 1110 feet

9. WATER LEVEL
 Static water level 505 164 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 61 °F Quality _____

Date started 11/16 1993
 Date completed 12/8 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name LAYNE-WESTERN, INC. Contractor
 Address 12030 E. RIGGS RD. Contractor
CHANDLER, AZ. 85249
 Nevada contractor's license number issued by the State Contractor's Board 0019101
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1616
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 1-29-94