WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44426
Permit No.
Basin 087

NOTICE OF INTENT NO. Z1892

1. OWNER U.S. Geological Survey-WRD
MAILING ADDRESS 333 W. Nye Lane Carson City Nv 89706 (887-7600)
ADDRESS AT WELL LOCATION Gregg St, approx 100 feet E. of Industrial Way and in dirt lot of Incline Overhead door Company

2. LOCATION SW ¼ SE ¼ Sec. 8 T. 19 (N) S R. 20 E. Washoe County
PERMIT NO. MO-769 (Issued by Water Resources) Parcel No. Gregg Street Well (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Auger Rig

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	2	2
Silty fine Sand		2	4	2
Well rounded Gravel		4	6	2
Mixed fine to Coarse Sand, pea gravel and Silty Clay + Moist		6	8	2
Gravel - Very hard		8	11	3
Gravel - Well Sorted pebbles (1-10 cm)		11	13	2
Gravel with interstitial Sand and Silt		13	16	3

Date started May 2, 1994
Date completed May 2, 1994

7. WELL TEST DATA
TEST METHOD [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 16 Feet Depth Cased 15 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
6 1/2	0	16

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC (Sch 40) Screw Type Joints		0	15

Perforations:
Type perforation Slot Type
Size perforation 0.020
From 10 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 0 to 5 ft
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 6 feet to 15 feet

9. WATER LEVEL
Static water level 12.76 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature °F Quality Unknown as yet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Armando Robledo - U.S.G.S. (Contractor)
Address 333 W. Nye Lane (Contractor)
Carson City Nv 89706 (887-7600)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller FP 1859
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10 May 94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627