

Plugged by NOI 64301

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY
Deepened by NOI # 64297
PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 4443
Permit No. _____
Basin. 083

NOTICE OF INTENT NO 25194

1. OWNER Ken Harris ADDRESS AT WELL LOCATION Same
MAILING ADDRESS 710 Cartwright Virginia City
2. LOCATION SE 1/4 SE 1/4 Sec. 31 T. 18 N. R. 21 E. Storey County
PERMIT NO. 003-452-01 B. Parcel No. 1/21.01 Subdivision Name Virginia City Highlands

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Yellow Claystone		0	40	40
Blue Claystone		40	60	20
Yellow Claystone		60	90	30
Blue Claystone		90	140	50
Hard Blue rock		140	440	300
Fractured	320			
"	390			
"	410			
39.377222°N 119.662367°W N 70 27 (W)				
MAY 17 11 02 AM '94 STATE ENGINEERS OFFICE				

8. WELL CONSTRUCTION
Depth Drilled 440 Feet Depth Cased 440 Feet
HOLE DIAMETER (BIT SIZE)
From To
10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 440 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>.188</u>	<u>+1</u>	<u>440</u>

Perforations:
Type perforation Factory Milled
Size perforation 3/32
From 360 feet to 400 feet
From 420 feet to 440 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 440 feet

9. WATER LEVEL
Static water level 2.80 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality Clean

Date started May 5, 1994
Date completed May 12, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>207</u>		<u>3 hrs</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Enloe Drilling Contractor
Address P.O. Box 1345 Contractor
Dayton, Nev
Nevada contractor's license number 4739 A
issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1480
Signed Loe A. Enloe
By driller performing actual drilling on site or contractor
Date May 12 1994