

OFFICE USE ONLY
 Log No. 44460
 Permit No. _____
 Basin 088

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23917

1. OWNER Greg Henderson ADDRESS AT WELL LOCATION 115 Andrew Lane Reno NV
 MAILING ADDRESS 115 Andrew Lane Reno NV
 2. LOCATION NE 1/4 SW 1/4 Sec 4 T. 17 S. R. 20 E Washoe County
 PERMIT NO. 17-350-42 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulders + clay		0	38	38
Clay Part		38	62	24
Sand		62	67	5
Clay Sandy		67	103	36
Sand + Small Gravel	✓	103	116	13
Gravel, lightly cemented	✓	116	180	64

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 100 Feet
2 3/8 Inches 100 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>12.97</u>	<u>0.188</u>	<u>0</u>	<u>180</u>

Perforations:
 Type perforation factory mill slot
 Size perforation 3/32
 From 120 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 180 feet

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name M/K/Kay Drilling Contractor
 Address 2290 Pioneer Drive Contractor
Reno, Nevada 89509
 Nevada contractor's license number 14170 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652
 Signed Steve PWS
 By driller performing actual drilling on site or contractor
 Date 5/17/94

Date started 5-3, 1994
 Date completed 5-6, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>74</u>	<u>92</u>	<u>5</u>
<u>perapirep level 50'</u>		

194 MAY 18 AM 11:57
 RECEIVED
 STATE ENGINEERS OFFICE