WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44482
Permit No.
Basin 103

NOTICE OF INTENT NO. 24486

1. OWNER Terry Fuller
MAILING ADDRESS 251 Woodlake Cir Dayton NV. 89403
ADDRESS AT WELL LOCATION 105 Rancho Rd Dayton NV. 89403

2. LOCATION SE ¼ SW ¼ Sec. 14 T. 16 N/S R. 22 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 19-541-04 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden Blow Sand		0	4	4
Hardpack Clay		4	6	2
Soft Sands		6	17	11
Brown Clay		17	50	33
Volcanic Gravels W/Seem of Clay		50	70	20
Brown Gummy Clay		70	95	25
Broken Volcanic Sands		95	104	9
Clays W/Inbeded Gravels		104	145	41
Brown Solid Clay		145	205	60
Clay Seem W/small Volcanic Sands		205	240	35
Larger Volcanic Sands	XXX	240	265	25

Date started 5-29, 1994
Date completed 6-2, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	75	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 1/4 Inches		0 Feet	60 Feet
9 7/8 Inches		60 Feet	265 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	265

Perforations:
Type perforation Mill Slot
Size perforation 3 X 3/32
From 225 feet to 265 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 265 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. Contractor
Address 5551 Hwy 50 East Carson City, Nevada 89 Contractor 885-1800
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L. Hack
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627