

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 0244

1. OWNER David Wilkins ADDRESS AT WELL LOCATION 10500 Wagon Ho Lane Reno, NV 89506  
 MAILING ADDRESS 10500 Wagon Ho Lane Reno, NV 89506  
 2. LOCATION N 1/4 S.W. 1/4 Sec. 25 T. 21 N. S. R. 18 E. Washoe County  
 PERMIT NO. 86-340-15 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	60	60
Coarse Sand		60	65	5
Brown Clay		65	75	10
Tule Gravel		75	77	2
Black tulle Clay		77	100	23
Black Quicksand		100	106	6
Brown Clay		106	110	4
Sand-fine		110	120	10
Brown Clay		120	150	30
Coarse Sand & Gravel X		150	162	12

8. WELL CONSTRUCTION  
 Depth Drilled 162 Feet Depth Cased 162 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10' Inches 0 Feet 52 Feet  
6 Inches 0 Feet 162 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.77</u>	<u>.188</u>	<u>0</u>	<u>162</u>

Perforations:  
 Type perforation Milled  
 Size perforation 1 1/8 x 3  
 From 160 feet to 153 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From feet to feet

9. WATER LEVEL  
 Static water level 55' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

Date started 19 Apr 1994  
 Date completed 25 Apr 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>5'</u>	<u>7</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Vernon Cannon Jr. Contractor  
 Address 4555 Hwy 50 W Silver Springs, NV 89429  
 Nevada contractor's license number issued by the State Contractor's Board 23317  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1455  
 Signed Vernon Cannon Jr.  
 By driller performing actual drilling on site or contractor  
 Date 27 Apr 94