

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 4497
 Permit No. 105
 Basin 105

NOTICE OF INTENT NO. 24596

1. OWNER WESTWINDS CONSTRUCTION ADDRESS AT WELL LOCATION 1937 CATHERINE
 MAILING ADDRESS GARDNERVILLE GARDNERVILLE

2. LOCATION NW 1/4 NE 1/4 Sec. 1 T. 12 N. R. 20 E. DOUGLAS County
 PERMIT NO. 23-480-54 WILDFLOWER Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/COBBLES		0	17	17
CEMENTED GRAVEL		17	31	14
SANDY CLAY w/GRAVEL		31	102	71
CEMENTED GRAVEL		102	174	72
SANDY CLAY		174	287	113
CLAY		287	294	7
SANDY CLAY w/GRAVEL		294	371	77
SANDY GRAY CLAY		371	445	74
SAND + GRAVEL	✓	445	455	10
SANDY CLAY		455	464	9
SAND + GRAVEL	✓	464	471	7
SANDY CLAY		471	480	9

8. WELL CONSTRUCTION
 Depth Drilled 480 Feet Depth Cased 480 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 480 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>480</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 440 feet to 480 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 480 feet

9. WATER LEVEL
 Static water level 175 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature WARM °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD Contractor
FALLON, NV 89406
 Nevada contractor's license number 27673
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1726
 Division of Water Resources, the on-site driller.
 Signed Pat A. Mooney
 By driller performing actual drilling on site or contractor
 Date 4-28-94

Date started 94 4-14 1994
 Date completed 4-28 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>3</u>

MAY 23 4 12 P M
 STATE ENGINEERS OFFICE