

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 44499
 Permit No. 105
 Basin I

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24930

1. OWNER LARRY LUTZ ADDRESS AT WELL LOCATION 623 STAGECOACH GARDNERVILLE
 MAILING ADDRESS 623 STAGECOACH GARDNERVILLE

2. LOCATION SE 1/4 SE 1/4 Sec 24 T. 12 N. R. 20 E. DOUGLAS County
 PERMIT NO. 29-104-02 RHVENSTROTH

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
gravel	X	230	232	2
Sandy clay w/ gravel		232	260	28
large gravel w/ sandy clay		260	268	8
Sandy clay		268	274	6
Cemented gravel	X	274	279	5
Sandy clay w/ gravel		279	284	5
gravel w/ some sandy clay		284	290	6
Cemented gravel	X	290	295	5

'94 MAY 23 P4:12
 RECEIVED
 STATE ENGINEERS DEPT.

8. WELL CONSTRUCTION
 Depth Drilled 230 Feet Depth Cased 295 Feet

HOLE DIAMETER (BIT SIZE)
 From 5 3/4 Inches To 230 Feet
295 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10	.188	215	295

Perforations:
 Type perforation Factory Slotted - T.C.
 Size perforation 3 1/2
 From factory 215 feet to 295 feet
 From T.C. 255 feet to 275 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 185 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535

Signed [Signature]
 By Driller performing actual drilling on site or contractor
 Date 5-3-94

Date started 4-27, 1994
 Date completed 5-3, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>9</u>		<u>10</u>