WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44506
Permit No.
Basin 106

NOTICE OF INTENT NO.

1. OWNER Mark Rogers
MAILING ADDRESS P.O. Box 806 Minden Nev. 89423
ADDRESS AT WELL LOCATION 3520 Topaz Park Road Topaz Lake Markleeville Nev.
2. LOCATION NW ¼ SE ¼ Sec. 29 T. 10 N/S R. 22 E. Douglas County
PERMIT NO. none (Issued by Water Resources) 39-200-02 (Parcel No.) none (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
alluvial small rocks + yellow dirt		0	165	165
sharp gravel	yes	165	174	9
yellow clay		174	180	6
hard rock		180	187	7
sharp gravel with some small seams of yellow clay	yes	187	240	53

'94 MAY 20 A10:52 STATE ENGINEER'S OFFICE

Date started May 6, 1994
Date completed May 18, 1994

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	20 ft	2 hrs

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	80 Feet	
6 Inches	80 Feet	240 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	240

Perforations:
Type perforation factory saw slott
Size perforation 3/32 X 3
From 170 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 80
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From — feet to — feet

9. WATER LEVEL
Static water level 105 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Mills (Contractor)
Address Box 92 Smith Nevada 89430 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Mills (By driller performing actual drilling on site or contractor)
Date May 19 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627