WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

34DEC

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44507
Permit No.
Basin 093

NOTICE OF INTENT NO. 23797

1. OWNER Fred and Bonnie Schopper
MAILING ADDRESS 1276 Matterhorn Blvd
Reno, Nv 89506

ADDRESS AT WELL LOCATION 5210 ~~1276~~ Matterhorn Blvd.
Parcel 1 of Map 1922

2. LOCATION NW ¼ SE ¼ Sec. 34 T. 22 N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 79-440-~~23~~ 51 (Parcel No.) — Antelope Valley Red Rock Est. # 308 (Subdivision Name) par B of par 1

3. WORK PERFORMED
XX New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
XX Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable XX Rotary ☐ RVC
XX Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black tan & white semi decomposed fractured granite		0	156	156
Black tan white D.G. with white clay		156	209	53
Tan white black green semi decomposed granite		209	463	254
Brown tan white D.G. fractured		463	683	220
Black white brown D.G. semi hard fractured		683	895	212
T.D. 895 ft				

Date started 10/5/93, 19
Date completed 10/13/93, 19

'94 MAY 25 A10:43
STATE ENGINEER'S OFFICE

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10+		3½

8. WELL CONSTRUCTION
Depth Drilled 895 Feet Depth Cased 895 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	57 Feet
8 ½ Inches	57 Feet	895 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 2	895

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 835 feet to 855 feet
From 875 feet to 895 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: XX Yes ☐ No
Depth of Seal 53 ft
Placement Method: ☐ Pumped XX Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: XX Yes ☐ No
From 53 feet to 895 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc (Contractor)
Address 625 Spice Islands Dr Suite L (Contractor)
Sparks, Nv 89431
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1132
Signed Roger Thrall (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall 10/14/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627