WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44524
Permit No.
Basin 101

NOTICE OF INTENT NO. 26362

1. OWNER Development Services
MAILING ADDRESS 1001 Pyramid Way
Sparks, NV 89431

ADDRESS AT WELL LOCATION
3600 Rice Road
Fallon, NV 89406

2. LOCATION NW ¼ SW ¼ Sec. 22 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. 52102 (Issued by Water Resources) | 008-211-26 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	10	10
Brown Clay		10	18	8
Brown Sand		18	30	12
Gray Clay		30	35	5
Coarse Gray Sand		35	75	40
Coarse Brown Sand		75	90	15
Black Clay		90	110	20
Gray Sand		110	123	13
Gray Clay		123	135	12
Gray Sand		135	155	20
Brown Clay		155	158	3
Brown Coarse Sand	X	158	180	22

'94 MAY -2 P1:25 STATE ENGINEER'S OFFICE

Date started 4/11, 1994
Date completed 4/14, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
16 Inches	0 Feet	180 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4	33.40	.250	0	180

Perforations:
Type perforation Mill Cut
Size perforation 1/8
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 180 feet

9. WATER LEVEL
Static water level 24 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, INc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons (By driller performing actual drilling on site or contractor)
Date 4-29-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627