WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44539
Permit No.
Basin 179

NOTICE OF INTENT NO. 23234

1. OWNER: Cecil Weaver
MAILING ADDRESS: HC 33 Box 33510 Ely NV 89301
ADDRESS AT WELL LOCATION: 21 W. 250 N. Cross timbers Sub.

2. LOCATION: SW ¼ NE ¼ Sec. 22 T. 17 N/S R. 63 E White Pine County
PERMIT NO.: NA (Issued by Water Resources) | Parcel No.: 5-591-21 | Subdivision Name: Cross timbers Land Co.

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TopSoil		0	2	
Sand gravel Cobble		2	19	
Sandy Clay		19	22	
gravel conglomerate		22	42	
Silty Clay		42	70	
gravel		70	71	
Silt Clay		71	77	
gravel	water	77	78	1
Silt Clay		78	96	
gravel	water	96	97	1
Clay		97	108	
gravel	water	108	111	3
Clay		111	130	
gravel	water	130	130.5	.5
Clay		130.5	135	
gravel	water	135	136	1
Clay		136	147	
gravel	water	147	148	
clay		148	150	

'94 MAY 24 A11:49 STATE ENGINEER'S OFFICE

Date started: May 5, 1994
Date completed: May 18, 1994

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	17	1 hr.

8. WELL CONSTRUCTION
Depth Drilled: 150 Feet Depth Cased: 150 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 Inches		50 Feet	150 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.1	.188	0	150

Perforations:
Type perforation: mill
Size perforation: 8 x 2½ x 6 row
From feet to feet
From 87 feet to 108 feet
From 129 feet to 150 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level: 78 feet below land surface
Artesian flow: G.P.M. P.S.I.
Water temperature: Cold °F Quality: good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: Nathan R Maynard (Contractor)
Address: Po Box 176 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board: 0022869
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1556
Signed: Owen Maynard (By driller performing actual drilling on site or contractor)
Date: May 19-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627