WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44546
Permit No.
Basin 137B

NOTICE OF INTENT NO. 22327

1. OWNER Round Mountain Gold Corp.
MAILING ADDRESS P.O. Box 480
Round Mountain, NV 89045

ADDRESS AT WELL LOCATION
NW Test #2 Minesite
site F-1

2. LOCATION SW ¼ SW ¼ Sec. 19 T. 10 N/S R. 44 E. Nye County

PERMIT NO. Waiver MO 671 A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluv. - granite		0	610	610
Domination				
Tuffs - Dominate		610	720	110
Volcanics				
Lake bed sediments	✓	720	790	70
Bedrock		790	880	90

Date started 5-16, 1994
Date completed 6-2, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	N/A	

8. WELL CONSTRUCTION
Depth Drilled 880 Feet Depth Cased 880 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
14¾ Inches	0 Feet	20 Feet
10⅝ Inches	20 Feet	880 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12¾	33.38	.250	+1	20
6⅝	12.81	.188	+1	880

Perforations:
Type perforation Milled - 32 Row
Size perforation ⅛"
From 770 feet to 875 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Envirosiving from 50' To 755'

Gravel Packed: ☒ Yes ☐ No
From 755 feet to 880 feet

9. WATER LEVEL
Static water level 687 feet below land surface
Artesian flow 25 G.P.M. P.S.I.
Water temperature 78 °F Quality Poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Waytek Drilling Co. (Contractor)
Address 2220 Steve Dr (Contractor)
Reno NV 89511

Nevada contractor's license number issued by the State Contractor's Board 0245-21

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442/1374

Signed Les Waytek (By driller performing actual drilling on site or contractor)

Date 6-24-94

JUN 28 '94 AM 11:42 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627