


WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 12531

1. OWNER United States Air Force ADDRESS AT WELL LOCATION Las Vegas Blvd
MAILING ADDRESS Nellis Air Force Base Near Sloan Rd.
North Las Vegas, Nev.

2. LOCATION NE 1/4 NE 1/4 Sec 3 T 20 N/S R 63 E Clark County

PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE Remediation WELL TYPE
 Domestic Irrigation Test Cable Rotary RVC
 Municipal/Industrial Monitor Stock Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Silt		0	13	13
Calichified Silt		13	22	9
Sandy Silt		22	38	16
Calichified Silt		38	42	4
Sandy Silt		42	48	6
Silty Clay		48	54	6
Sandy Silt		54	59	5
Caliche Pink		59	61	2
Silty Clay		61	68	7
Calichified Silt		68	84	16
Silty Clay	86'	84	88	4
Gravelly Clay		88	121	33

8. WELL CONSTRUCTION
Depth Drilled 121 Feet Depth Cased 129 Feet

HOLE DIAMETER (BIT SIZE)
From To
15" Inches 121 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"	SCH 80	AST 480-81	+3	57
10"	Sch 40	S.S. Sump	117	120

Perforations:
Type perforation Stainless Steel Slotted
Size perforation .020
From 57 feet to 117 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 53 Neat Cement Grout
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No 3% Benonite
From 53 feet to 121 feet

9. WATER LEVEL
Static water level 77.8 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Water Development Corp. Contractor
Address 1202 Kentucky Avenue Contractor
Woodland, Ca. 95776
Nevada contractor's license number issued by the State Contractor's Board 0012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1368
Signed J. Miller Smith
By driller performing actual drilling on site or contractor
Date _____

Date started 12-19 19 93
Date completed 12-22 19 93

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

94 MAY 16 P 2:39
STATE ENGINEERS OFFICE

RECEIVED
MAY 18 1994
Div. of Water Resources
Branch Office - Las Vegas, NV