

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 44665

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Log No. 1162
 Permit No. 1162
 Basin 1162
 NOTICE OF INTENT NO. 13276

1. OWNER MORGAN RUSSELL INC ADDRESS AT WELL LOCATION LOT 37 RETREAD RD
 MAILING ADDRESS PAHRUMP NV 89041

2. LOCATION NE 1/4 SE 1/4 Sec. 14 T. 20S N/S R 52 E NYE County NYE
 PERMIT NO. 28-732-05 CHARLESTON PARK
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	2	2
CALICHIE		2	4	2
CLAY		4	35	31
CALICHIE		35	38	3
CLAY		38	64	26
CALICHIE	WB	64	72	8
CLAY		72	95	23
CALICHIE	WB	95	101	6
CLAY		101	112	11
CALICHIE	WB	112	117	5
CLAY		117	121	4
CALICHIE	WB	121	128	7
CLAY		128	134	6
CALICHIE	WB	134	140	6
		140		140

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 140
121 1/4 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\8	16.9	.188	0	140

Perforations: **FACTORY SAW CUT**
 Type perforation _____
 Size perforation 1\8 X 3"
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED
 JUN 2 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL
 Static water level 46 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 5-23-94, 19_____
 Date completed 5-25-94, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. INC.
 Contractor
 Address HCR 78 BOX 80358
PAHRUMP NV 89041
 Nevada contractor's license number 30880
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1642
 Division of Water Resources, the on-site driller
 Signed Thomas De...
 By driller performing actual drilling on site or contractor
 Date 5/28/94