


PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



NOTICE OF INTENT NO. 13279

1. OWNER MICHAEL CLINE ADDRESS AT WELL LOCATION 3480 W RAMONA  
 MAILING ADDRESS PAHRUMP NV 89041

2. LOCATION NW 1/4 NE 1/4 Sec. 24 T. 20S N/S R. 52 E. 1 NYE County  
 PERMIT NO. 28-772-14 CHARLESTON PARK  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	3	3
CALICHIE		3	51	48
CLAY		51	22	29
CALICHIE		22	24	2
CLAY		24	47	23
CALICHIE		47	53	6
CLAY		53	61	8
CALICHIE	WB	61	64	3
CLAY		64	75	11
CALICHIE	WB	75	78	3
CLAY		78	89	11
CALICHIE	WB	89	92	3
CLAY		92	108	16
CALICHIE	WB	108	114	6
CLAY		114	123	9
CALICHIE	WB	123	127	4
CLAY		127	137	10
CALICHIE	WB	137	140	3
		140		140

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 To 140  
12 1/4 Inches Feet  
 \_\_\_\_\_ Inches Feet  
 \_\_\_\_\_ Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\8	16.9	.188	0	140

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 1\8 X 3"

From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

RECEIVED

JUN 29 1994

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 5-23-94 19\_\_\_\_  
 Date completed 5-27-94 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 49 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. INC.  
Contractor

Address HCR 78 BOX 80258  
PAHRUMP NV 89041  
Contractor

Nevada contractor's license number issued by the State Contractor's Board 30880

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed [Signature]  
 By driller performing actual drilling on site or contractor

Date 6-10-94

