WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44706
Permit No.
Basin 162

NOTICE OF INTENT NO. 13340

1. OWNER Keith L. Hughes
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1521 S. Redrock Dr.

2. LOCATION SE ¼ NW ¼ Sec. 21 T. 20-S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 39-162-12 (Parcel No.) Calvada Valley Unit 8-B (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown clay/caliche		4	12	8
Brown clay		12	32	20
Caliche		32	39	7
Grey clay	X	39	84	45
Brown clay	X	84	123	39
Brown clay/caliche	X	123	140	17

RECEIVED
JUN 14 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started May 20, 1994
Date completed May 20, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Cut
Size perforation 1/8" width 3" long (8 rolls)
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JIM PIKE WELL DRILLING, LLC (Contractor)
Address P.O. Box 56 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 17563
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1324
Signed (By driller performing actual drilling on site or contractor)
Date May 27, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627