

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **44733**
 Permit No. **212**
 Basin **212**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **10564**

1. OWNER SUMMA Corp ADDRESS AT WELL LOCATION Northeast corner Rancho Dr & Carey Ave
 MAILING ADDRESS 3800 Howard H. Pkwy
LV, NV 89109

2. LOCATION SE 1/4 SW 1/4 Sec 18 T 20 N 61 E CLARK County
 PERMIT NO. MD-2425A 110-090-001 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG **MW-5**

Material	Water Strata	From	To	Thick-ness
SANDY CLAY - brn		0	6	6
CALICHE - brn		6	10	4
SANDY CLAY - brn		10	18	8
CALICHE - brn		18	19	1
SANDY CLAY - brn	Y	19	21	2
CALICHE	Y	21	22	1
SANDY CLAY - brn	Y	22	33	11

8. WELL CONSTRUCTION
 Depth Drilled 33 Feet Depth Cased 33 Feet

HOLE DIAMETER (BIT SIZE)
 From 6 Inches To 0 Feet 33 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>33</u>

Perforations:
 Type perforation slotted
 Size perforation 0.010"
 From 33 feet to 18 feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 16
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 33 feet to 16 feet

9. WATER LEVEL
 Static water level 20.5 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature °F Quality

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ti Aen c/o WTI
 Address 3611 W Tompkins Ave
LV, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller MIF61
 Signed [Signature]
 Date 6/1/94

Date started 5/16, 1994
 Date completed 5/16, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 JUN 8 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV