

WHITE—DIVISION OF WATER RESOURCES
 CANARY—CLIENT'S COPY
 PINK—WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. **44749**
 Permit No. _____
 Basin O.G.

I

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25025

1. OWNER NEWMONT GOLD CO. ADDRESS AT WELL LOCATION
NEWDMONT GOLD MINE
 MAILING ADDRESS P.O. BOX 669
CARLIN NV 89822-0669 NEAR CARLIN
 2. LOCATION NW 1/4 NW 1/4 Sec. 29 T. 35 N/S R. 51 E. EUREKA County
 PERMIT NO. M/O 797 N/A Parcel No. N/A Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
RED ROCK AND BROWN CLAY		0	20	20
BLACK ROCK & BROWN CLAY		20	80	60
BLACK-BROWN & RED CLAY		80	85	5
BROWN CLAY-BLACK & RED ROCK		85	100	15
BLACK-BROWN & RED ROCK		100	105	5
BROWN CLAY BLACK & RED ROCK		105	305	200
BROWN CLAY & BLACK ROCK		305	405	100
BLACK RED & BROWN ROCK		405	505	100

8. WELL CONSTRUCTION
 Depth Drilled 505 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12-1/4 Inches 0 Feet 20 Feet
6-1/2 Inches 20 Feet 480 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7	28	.375	0	20
1-1/4	2	SCH40	0	480

Perforations:
 Type perforation SLOTTED
 Size perforation .125
 From 480 feet to 500 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 460 feet to 505 feet

Date started MAY 20, 1994
 Date completed MAY 22, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 125 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING
 Contractor
 Address 2286 WEST 1500 SOUTH
 Contractor
SALT LAKE CITY UT 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1717

Signed David Corley
 By driller performing actual drilling on site or contractor
 Date 06/10/94

JUN 23 11:56 AM '94
 RECEIVED
 STATE ENGINEERS OFFICE