



OFFICE USE ONLY  
 Log No. 44849  
 Permit No. M19 683  
 Basin 089

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23284

1. OWNER Parkview Estates ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS White Pine Drive  
New Washoe City NV  
 2. LOCATION SW 1/4 SE 1/4 Sec 6 T. 16 S. R. 20 E. Washoe County  
 PERMIT NO. M19 683 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG White Pine South

Material	Water Strata	From	To	Thick-ness
<u>Round Base</u>	<u>No</u>	<u>0</u>	<u>1.5</u>	<u>1.5</u>
<u>Sandy Silty Clay</u>	<u>No</u>	<u>1.5</u>	<u>4.5</u>	<u>3.0</u>
<u>Sand</u>	<u>Yes</u>	<u>4.5</u>	<u>34.0</u>	<u>29.5</u>

8. WELL CONSTRUCTION  
 Depth Drilled 34 Feet Depth Cascd. 34 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 0 Feet 34 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>5/16</u>	<u>0</u>	<u>34</u>

Perforations:  
 Type perforation Factory Slot  
 Size perforation 1.020 Inch  
 From 13.5 feet to 34 feet  
 From 13.5 feet to 34 feet  
 From 13.5 feet to 34 feet  
 From 13.5 feet to 34 feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 10.5  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 10.5 feet to 34 feet

9. WATER LEVEL  
 Static water level 14 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature Cold °F Quality N/A

Date started 7-7 1993  
 Date completed 7-7 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Business Exploration Drilling Contractor  
 Address 1635 Belford Rd. Reno NV Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 34525  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1667  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 07/11/93