



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23142

1. OWNER Greyhound ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 1460 West Second Street
Reno, NV
 2. LOCATION 1/4 Sec. 11 T. 19 S. R. 19 E. Washoe County
 PERMIT NO. M/0-175-A Parcel No. Greyhound/Bus Depot Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. MW-6 LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Concrete		0	0.5'	.5'
Brown silt w/trace Fine Sands		.5	2.5'	2'
Brown Med. Sands		2.5'	7'	4.5'
Brown Med.-Coarse Sands/Fine-Coarse		7'	12'	5'
Gravel				
Cobble & Boulder Fragments	21.4'	12'	28'	16'

94 JUN 20 P 2:53
 STATE ENGINEERS & SURVEYORS

8. WELL CONSTRUCTION
 Depth Drilled 28' Feet Depth Cased 28' Feet

HOLE DIAMETER (BIT SIZE)
8 Inches From 0 Feet To 28 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	1	Sch. 40	0	28'

Perforations:
 Type perforation Slotted
 Size perforation .020
 From 13 feet to 28 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 11' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 11' feet to 28' feet

9. WATER LEVEL
 Static water level 21.4 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 65 °F Quality Cloudy

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Gregory J. Lawler Contractor
 Address 1860 Obispo Ave Unit H
Signal Hill CA 90804 Contractor
 Nevada contractor's license number 34699
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the M 1871
 Division of Water Resources, the on-site driller.
 Signed James Gray
 By driller performing actual drilling on site or contractor
 Date 6-1-94

Date started June 1st 1994
 Date completed June 1st 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>120.5 Gal</u>		<u>1</u>