

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18109

1. OWNER SECURITY CAPITAL ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS SPARKS, NV. PRATER WAY & BOXINGTON WAY  
SPARKS, NV.  
 2. LOCATION NW 1/4 SW 1/4 Sec 2 T 19 N R 20 E WASHOE County  
 PERMIT NO. M/O 728 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG MW-1

Material	Water Strata	From	To	Thick-ness
<u>BROWN CLAYEY SILT</u>	<u>-</u>	<u>0</u>	<u>9'</u>	<u>9'</u>
<u>REDDISH BROWN SILTY CLAY</u>	<u>-</u>	<u>9'</u>	<u>12'</u>	<u>3'</u>
<u>BROWN SANDY CLAY</u>	<u>-</u>	<u>12'</u>	<u>18'</u>	<u>6'</u>
<u>GRAY CLAYEY SILT</u>	<u>-</u>	<u>18'</u>	<u>20'</u>	<u>2'</u>
<u>GRAY CLAYEY SAND</u>	<u>25'</u>	<u>20'</u>	<u>35'</u>	<u>15'</u>

194 JUN 16 P 1:36 STATE DIVISION OF WATER RESOURCES

8. WELL CONSTRUCTION  
 Depth Drilled 35 Feet Depth Cased 35 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 5 Inches To 35 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>SCH. 40</u>	<u>PVC</u>	<u>0</u>	<u>35</u>

Perforations:  
 Type perforation FACTORY SLOT  
 Size perforation 0.01"  
 From 20 feet to 35 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 18'  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 18 feet to 35 feet

9. WATER LEVEL  
 Static water level 25 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature COLD °F Quality N/A

Date started 10/29 1993  
 Date completed 10/29 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
		<u>N/A</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ANDRESEN EXPLORATION DRILLING  
 Contractor  
 Address 1635 BELFORD RD.  
RENO, NV. 89509  
 Contractor  
 Nevada contractor's license number 0034525  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the # 1028  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 6/11/94