WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44891
Permit No.
Basin 6 - 687

NOTICE OF INTENT NO. 18140

1. OWNER PACKER WAY SERVICE CTR.
MAILING ADDRESS SPARKS, NV.
ADDRESS AT WELL LOCATION 802-996 PACKER WAY SPARKS, NV.

2. LOCATION NE ¼ SW ¼ Sec. 10 T. 19 (N) S R. 20 E. WASHOE County
PERMIT NO. M/O 712 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG MW-2

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| BROWN SILTY CLAY | | 0' | 13' | 13' |
| BROWN SANDY CLAY | 37' | 13' | 46' | 33' |

RECEIVED
JUN 16 1994
STATE ENGINEER'S OFFICE

Date started 10/18, 1993
Date completed 10/19, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | N/A | |

8. WELL CONSTRUCTION
Depth Drilled 46 Feet Depth Cased 46 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 5 Inches | 0 Feet | 46 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | SCH. 40 | PVC | 0 | 46 |
| | | | | |

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.01"
From 21 feet to 46 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 19'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 19 feet to 46 feet

9. WATER LEVEL
Static water level 37 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANDRESEN EXPLORATION DRILLING (Contractor)
Address 1635 BELFORD RD. (Contractor)
RENO, NV. 89509
Nevada contractor's license number issued by the State Contractor's Board 0034525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller [redacted] M 1881
Signed (By driller performing actual drilling on site or contractor)
Date 6/1/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627