WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44902
Permit No.
Basin 8-101

NOTICE OF INTENT NO. 26375

1. OWNER Walt Johnson
MAILING ADDRESS 4510 Reno Hwy
Fallon, NV 89406

ADDRESS AT WELL LOCATION
3090 Boyer Road
Fallon, NV 89406

2. LOCATION NW ¼ NW ¼ Sec 8 T 18 N/S R 28 E/W Churchill County
PERMIT NO. (Issued by Water Resources) 006-301-18 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0 | 10 | 10 |
| Brown Clay | | 10 | 18 | 8 |
| Brown Sand | | 18 | 25 | 7 |
| Grey Clay | | 25 | 36 | 11 |
| Fine Brown Sand | | 36 | 45 | 9 |
| Coarse Brown Sand | X | 45 | 57 | 12 |

Date started 5-17, 19 94
Date completed 5-17, 19 94

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 57 Feet Depth Cased 57 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 Inches | 0 Feet | 57 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | 0 | 57 |
| | | | | |

Perforations:
Type perforation Mill Cut
Size perforation 1/8
From 52 feet to 55 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 57 feet

9. WATER LEVEL
Static water level 10' 8" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons (By driller performing actual drilling on site or contractor)
Date 6-21-94

JUN 22 AM 12 '94 STATE ...

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627