

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 44937
 Permit No. 105
 Basin. 105

NOTICE OF INTENT NO. 25335

1. OWNER Pete Cortes ADDRESS AT WELL LOCATION 825 Buckskin cct
 MAILING ADDRESS PO Box 557 Carson City NV 89410
 2. LOCATION NE 1/4 NW 1/4 Sec. 19 T. 12 N/S R. 21 E. Douglas County
 PERMIT NO. 29-530-05 Parcel No. Ru hn street Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--------------------|--------------|------|-----|------------|
| SAND & Gravel | | 0 | 15 | |
| Gravel | | 15 | 35 | |
| SAND & Gravel | | 35 | 75 | |
| SAND & ROCK | | 75 | 85 | |
| SAND CLAY & Gravel | | 85 | 130 | |
| SAND | | 130 | 170 | |
| SAND & Gravel | | 170 | 195 | |
| SAND & ROCK | | 195 | 240 | |
| CLAY & GRAVELS | | 240 | 285 | |
| CLAY SAND Gravel | | 285 | 300 | |
| CLAY & Gravel | | 300 | 320 | |
| Gravel | | 320 | 340 | |

8. WELL CONSTRUCTION
 Depth Drilled.....Feet Depth Cased 340 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet 340 Feet
Inches.....Feet.....Feet
Inches.....Feet.....Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u> | <u>12.56</u> | <u>.188</u> | <u>0</u> | <u>340</u> |

Perforations:
 Type perforation Factory & hand cut
 Size perforation 3" x 5/32"
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 340 feet to 50 feet

9. WATER LEVEL
 Static water level 145 feet below land surface
 Artesian flow.....G.P.M.....P.S.I.
 Water temperature.....°F Quality.....

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Krausack Drilling Inc Contractor
 Address PO Box 1359 Minden NV Contractor
 Nevada contractor's license number #021268
 issued by the State Contractor's Board
 Nevada driller's license number issued by the #1495
 Division of Water Resources, the on-site driller
 Signed Michael Allen
 By driller performing actual drilling on site or contractor
 Date 3-28-94

Date started 3-13 1994
 Date completed.....19.....

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|------------|------------|-------------------------------|--------------|
| <u>Air</u> | <u>30+</u> | | |

'94 JUN 23 AM 12:29
 RECEIVED
 STATE ENGINEERS OFFICE