

OFFICE USE ONLY
 Log No. 44956
 Permit No. _____
 Basin. 101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26338

1. OWNER Charles Geurich ADDRESS AT WELL LOCATION 2295 Thurman Lane
 MAILING ADDRESS 2295 Thurman Lane

2. LOCATION SW 1/4 SE 1/4 Sec 23 T 19 N/S R 28 E Churchill County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand	✓	0	16	16
Brown Clay		16	21	5
Brown Sand	✓	21	33	12
Black Sand	✓	33	49	16
Black Silt	✓	49	65	16
Gray Sand	✓	65	85	20
Brown Sand	✓	85	100	15

94 JUN 16 P 1:33
 STATE ENGINEERING

8. WELL CONSTRUCTION
 Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches 2 Feet 50 Feet
 To 6 Inches 50 Feet 100 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>71</u>	<u>100</u>

Perforations:
 Type perforation machine slot
 Size perforation .050

From _____ feet to _____ feet
 From 90 feet to 97 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 18-9 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started April 24, 1994
 Date completed April 26, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>		<u>1</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Contractor
 Address Box 588 Fallon NV Contractor

Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772

Signed Welsco
 By driller performing actual drilling on site or contractor
 Date April 28-94