



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24669

1. OWNER Louis Karcher ADDRESS AT WELL LOCATION 3470 Antelope St. Silver Springs, NV 89429  
 MAILING ADDRESS 213 McKinley Place Ridgewood N.J. 07450  
 2. LOCATION NW 1/4 NW 1/4 Sec. 01 T. 17 N. S. R. 25 E. Lyon County  
 PERMIT NO. 17-374-01 Parcel No. Stockton Sub 49 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fine to coarse sand		0	30	
Brown Clay		30	63	
Fine to coarse sand	X	63	118	
Gray Clay	X	118	120	

'94 JUN -9 AIO:47  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 120 Feet Depth Cased 120 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 120 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>120</u>

Perforations:  
 Type perforation Mill  
 Size perforation 1/8 x 3  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 120 feet

9. WATER LEVEL  
 Static water level 30 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge  
 Name ACE Drilling & Dev.  
 Address P.O. Box 668 Silver Springs, NV, 89429  
 Nevada contractor's license number 14299  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 6/8/94

Date started 6/1 1994  
 Date completed 6/3 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>18</u>	<u>5</u>	<u>2</u>