WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45000
Permit No.
Basin 8-103

NOTICE OF INTENT NO. 25527

1. OWNER Mac Calico Realty
MAILING ADDRESS 8500 Hiway 50 W
Silver Springs, NV

ADDRESS AT WELL LOCATION
8965 Hwy 50 W
Stagecoach, NV

2. LOCATION SW ¼ NW ¼ Sec. 11 T. 17 N/S R. 23 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 19-382-01 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	15	15
Brown Clay		15	18	3
Gravel		18	28	3
Brown Clay		28	30	2
Sand & Gravel		30	45	15
Brown Sandy Clay		45	50	5
Sand & Gravel		50	67	17
Brown Clay		67	70	3
Sand & Gravel		70	80	10
Clay & Sand		80	110	30
Gravel & Clay	X	110	150	40

'94 JUN 23 A10 27
STATE ENGINEER'S OFFICE

Date started May 9, 19 94
Date completed May 10, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 3/4 Inches	0 Feet	150 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	150

Perforations:
Type perforation Mill Cut
Size perforation 1/8
From 110 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 58 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons (By driller performing actual drilling on site or contractor)
Date 6-7-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627