

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26950

1. OWNER Jim Wood Devp ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3595 Arcadia Dr 3572 Arcadia Dr
Carson City, Nev Carson City
 2. LOCATION NE 1/4 NE 1/4 Sec 12 T 14 N/S R 19 E Douglas County
 PERMIT NO. 13-071-07 James Wood Parcel Map lot 2
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DG Sand		0	80	80
Green DG Sand		80	110	30
soft rock Decomp		110	150	40
	*	40	50	
	*	120	140	

94 JUN 16 AM 11:13
 STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 150 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>		<u>.188</u>	<u>+1</u>	<u>150</u>

Perforations:
 Type perforation Factory Milled
 Size perforation 3/32
 From _____ feet to _____ feet
 From 130 feet to 150 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 150 feet

9. WATER LEVEL
 Static water level 4.0 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Clear

Date started May 21 1994
 Date completed May 21 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>1 hr</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Enloe Drilling Contractor
 Address P.O. Box 1345 Contractor
Dayton, Nev
 Nevada contractor's license number 4739A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1480
 Signed Lee A Enloe
 By driller performing actual drilling on site or contractor
 Date May 23 1994