WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45003
Permit No.
Basin 107

NOTICE OF INTENT NO. 24499

1. OWNER Carson Dept of Public Works
MAILING ADDRESS 3300 Butti #9, Carson City, NV 89701
ADDRESS AT WELL LOCATION Corner of Prospect Dr. & Upland 3209 Prospect, Carson City, NV 89701

2. LOCATION SE ¼ SE ¼ Sec. 2 T. 15N N/S R. 19 E. Carson County
PERMIT NO. 26497 (Issued by Water Resources) 7-26-261-24 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
The well is an 8" cased well that we found to be 385' deep. We perforated the casing using a mills knife tool at 10' intervals with three perforations at each level approximately 120° apart. Static water level was 85'. We used approximately 7-8 cu. yards of neat cement slurry and filled from the bottom of the hole to the top. We cut the casing off 3' from surface.				
This well was refered to as well #17.				

Date started 5-2, 1994
Date completed 5-3, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"		.188		

Perforations:
Type perforation Mills Knife
Size perforation
From 55 feet to bottom of casing.
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 85' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MacKay Pump & Geothermal, Inc. (Contractor)
Address 1600 Mt. Rose Hwy. (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on site or contractor)
Date 5-3-'94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627