WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 45004
Permit No.
Basin 104

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Crestview Trailer Park ADDRESS 600 Hot Springs Rd Carson City NV

2. LOCATION NE ¼ SW ¼ Sec. 8 T. 15 N/S R. 20 E. Carson County
PERMIT NO.

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☒

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandonment of 6 inch well 92 feet - work done with Mills perforator knife				
4 Rows every 6 inches 3 inches long 92 feet				
Neat cement pumped with grout pumper from bottom to top 5 yds neat cement				
Inspection overseen by Tom Gallager State Engineers				

Date started 1-19, 19 94
Date completed 1-23, 19 94

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 92 feet
Casing record
Weight per foot Thickness .188

Diameter	From	To
6 inches	0 feet	92 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type Neat Cement
Depth of seal feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 25 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Marvin & Sons Drilling
Address 4340 Hwy 50 E CC
Nevada contractor's license number 018884
Nevada driller's license number 707
Signed Anthony Marvin
Date 1-31-94

USE ADDITIONAL SHEETS IF NECESSARY

O-627

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 45004
Permit No.
Basin 104

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Crestview Trailer Park ADDRESS 600 Hot Springs Rd Carson City Nev

2. LOCATION NE ¼ SW ¼ Sec. 8 T. 15 N/S R. 20 E. Carson County
PERMIT NO.

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☒

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandonment of 6 inch well 92 feet - work done with Mills perforator knife				
4 Rows every 6 inches 3 inches long 92 feet				
Neat cement pumped with grout pumper from bottom to top litgok 5 yds neat cement				
Inspection overseen by John Gallager State Engineers				

Date started 1-19, 19 94
Date completed 1-23, 19 94

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 92 feet
Casing record
Weight per foot Thickness .188

Diameter	From	To
6 inches	0 feet	92 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type Neat Cement
Depth of seal feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 25 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Marcin & Sons Drilling
Address 4340 Hwy 50 E - C.C.
Nevada contractor's license number 018884
Nevada driller's license number 707
Signed Anthony Marcin
Date 1-31-94

USE ADDITIONAL SHEETS IF NECESSARY

O-627