

OFFICE USE ONLY  
 Log No. 45621  
 Permit No. I  
 Basin. 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24937

1. OWNER MR. McCUE ADDRESS AT WELL LOCATION 994 RUBIO  
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION NW 1/4 NE 1/4 Sec 17 T. 12 N. R. 20 E. DOUGLAS County  
 PERMIT NO. 27-070-29 CHARLEBOIS Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>cobbles, gravel 1/2 sandy</u>		<u>0</u>	<u>80</u>	<u>80</u>
<u>sandy clay</u>		<u>80</u>	<u>84</u>	<u>4</u>
<u>gravel 1/2 sandy clay</u>		<u>84</u>	<u>102</u>	<u>18</u>
<u>sandy clay 1/2 gravel</u>		<u>102</u>	<u>108</u>	<u>6</u>
<u>gravel 1/2 same sandy clay</u>	<u>W</u>	<u>108</u>	<u>140</u>	<u>32</u>

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 140 Feet  
 Inches Feet Feet Feet  
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Factory Slotted  
 Size perforation 3x3/32  
 From 140 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 100 feet to 140 feet

9. WATER LEVEL  
 Static water level 35 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature solid °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD Contractor  
FALLON, NV 89406  
 Nevada contractor's license number 27673  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1535  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 6-13-94

Date started 6-9 1994  
 Date completed 6-13 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>	<u>-</u>	<u>1</u>
<u>Air</u>	<u>25+</u>	<u>-</u>	<u>1</u>

'94 JUL -6 AM 11:21  
 STATE ENGINEERS OFFICE