

OFFICE USE ONLY
 Log No. 40306
 Permit No. _____
 Basin 8-05
 25269

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER U.S. Fish & Wildlife ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 911 NE 11th Avenue Lahontan National Fish Hatchery
Portland, Oregon 97232

2. LOCATION NE 1/4 NW 1/4 Sec 23 T. 12 N. R. 20 E Douglas County _____
 PERMIT NO. 57987T / 57985T Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy soil & Clay		0	5	5
Sand, Gravels & Cobbles		5	168	163
Sands & Gravels with layers of hard black rock		168	560	392
Brown & Gray clay with Layers of gravel		560	595	35
Gravel & sands with thin layer clays		595	700	105

8. WELL CONSTRUCTION

Depth Drilled 700 Feet Depth Cased 700 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
32	0	100
24	100	700

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
26"	102.63	.375	+ 1	100
16"	42.05	.250	+ 2	700

Perforations:
 Type perforation Triple Mill Slot
 Size perforation .125 x 3"
 From 160 feet to 700 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 0 feet to 700 feet

9. WATER LEVEL

Static water level 31.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sargent Irrigation Company Contractor
 Address 9955 North Virginia Street
Reno, Nevada 89506 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0021246
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1493

Signed [Signature] By driller performing actual drilling on site or contractor
 Date 7/6/94

Date started 02/18/ 1994
 Date completed 03/09/ 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
600	190.65	24

'94 JUL 14 P 2:53
 STATE ENGINEERS OFFICE