WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40306 - Well drilled originally
Permit No.
Basin 8-05

NOTICE OF INTENT NO. 25271

1. OWNER U.S. Fish & Wildlife
MAILING ADDRESS 911 NE 11th Avenue
Portland, Oregon 97232

ADDRESS AT WELL LOCATION
Lahontan National Fish Hatchery
Gardnerville, Nevada

2. LOCATION NE ¼ NW ¼ Sec. 23 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. 57987T / 57985T (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Perforate casing with Mills Knife at 140', 120', 80' and 40'				
Tremme pipe was installed to 700' and abandonment gel was circulated through hole. After viscosity was raised to 59 seconds and weight was 9.3 pounds per gallon. We then installed a 50' neat cement seal.				

'94 JUL 14 P2:53 STATE ENGINEER

Date started March 16, 19 94
Date completed March 18, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation Triple Mill Slot
Size perforation .125 x 3"
From 160 feet to 700 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sargent Irrigation Company (Contractor)
Address 9955 North Virginia Street (Contractor)
Reno, Nevada 89506
Nevada contractor's license number issued by the State Contractor's Board 0021246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1493
Signed Dan Pearson (By driller performing actual drilling on site or contractor)
Date 7-6-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627