

Log No. 45026
Permit No. 105
Basin FOOTHILL/LEWALLEN

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24933

1. OWNER JIM KINGBETT ADDRESS AT WELL LOCATION 310 FOOTHILL RD
MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION NE 1/4 NW 1/4 Sec 36 T. 12 N. R. 20 E DOUGLAS County
PERMIT NO. 19-300-61 Parcel No. FOOTHILL/LEWALLEN Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>sand w/ boulders</u>		<u>0</u>	<u>23</u>	<u>23</u>
<u>boulders w/ sandy clay coarse sand</u>		<u>23</u>	<u>205</u>	<u>182</u>
<u>boulders w/ sandy clay</u>		<u>205</u>	<u>216</u>	<u>11</u>
<u>sandy clay w/ DG</u>		<u>216</u>	<u>220</u>	<u>4</u>
<u>boulders w/ some sandy clay</u>	<u>X</u>	<u>220</u>	<u>225</u>	<u>5</u>
<u>Sandy clay</u>		<u>225</u>	<u>228</u>	<u>3</u>
<u>boulder w/ some sandy clay</u>	<u>X</u>	<u>228</u>	<u>260</u>	<u>32</u>
<u>sandy clay w/ DG</u>		<u>260</u>	<u>267</u>	<u>7</u>
<u>boulders w/ some sandy clay</u>	<u>X</u>	<u>267</u>	<u>275</u>	<u>8</u>
<u>Sandy clay w/ DG</u>		<u>275</u>	<u>280</u>	<u>5</u>

194 JUL -6 AM 11:22
STATE ENGINEERING CO.

NEW APN# 1219-36-001-003

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)
From 0 To 280
10 5/8 Inches Feet
Inches Feet
Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>280</u>

Perforations:
Type perforation Factory slotted / T.C.
Size perforation 3x3/4
From Factory 260 feet to 280 feet
From T.C. 200 feet to 260 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 280 feet

9. WATER LEVEL
Static water level 11.2 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality good

Date started 5-11, 1994
Date completed 6-7, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Air</u>	<u>257</u>		<u>3</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDGO EXPLORATION, INC Contractor
Address 7780 CURRY RD. Contractor
FALLOON, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535

Signed [Signature] By driller performing actual drilling on site or contractor
Date 6-7-94