

OFFICE USE ONLY  
 Log No. 47002  
 Permit No. 105  
 Basin. 23350

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23350

1. OWNER Bobara Ward ADDRESS AT WELL LOCATION 1610 Scott Ln  
 MAILING ADDRESS 1610 Scott Ln GARD NV 89410 GARD NV  
 2. LOCATION SE 1/4 SE 1/4 Sec. 34 T 13 N/S R. 20 E Douglas County  
 PERMIT NO. 23-412-03 Parcel No. N/A Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0	16	
Sand + clay	X	16	38	
Sand Gravel + clay		38	56	
Gravel + Sand		56	145	
clay		145	155	

94 JUN 13 AMT 445  
 STATE ENGINEER

8. WELL CONSTRUCTION  
 Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 Inches To 0 Feet 155 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	7 lbs	.188	0	155

Perforations:  
 Type perforation Factory Pent  
 Size perforation 3 X 5/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 135 feet to 155 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 17' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

Date started 6/27 19 94  
 Date completed 7/5 19 94

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR Lift</u>	<u>+ 50 gpm</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Kawchock Drilling Inc Contractor  
 Address PO Box 1359 Minden NV Contractor  
 Nevada contractor's license number #021268 issued by the State Contractor's Board.  
 Nevada driller's license number #1380 issued by the Division of Water Resources (the on-site driller)  
 Signed Ed Kawchock  
 By driller performing actual drilling on site or contractor  
 Date 7/6/94