WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45033
Permit No.
Basin 105

NOTICE OF INTENT NO. 26809

1. OWNER John Pagan
MAILING ADDRESS 1530 Wildflower PO Box 2873 Gardnerville NV. 89410
ADDRESS AT WELL LOCATION 1561 Sawmill Rd Gardnerville NV. 89410

2. LOCATION NE ¼ NE ¼ Sec. 35 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. Issued by Water Resources
23-472-37 Parcel No.
None Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
Hard Pack Clay		3	8	5
Large 1/4" Gravels		8	75	67
Small Gravels w/ Small Clay Seams		75	92	17
Brown Clay (Sandy)		92	170	88
Small Obsidian gravels		170	182	12
Brown Clays		182	210	28
Clays w/ Small Inbedded Gravels		210	240	30
Solid Brown Clay		240	251	11
Small Gravels w/ Small Clay Seams		251	320	69

Date started 5-3, 1994
Date completed 5-6, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	60	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 320' Feet Depth Cased 320' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 1/4 Inches		0 Feet	55 Feet
10 3/4 Inches		55 Feet	320 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	13.03	.188	0	320

Perforations:
Type perforation Mill Slot
Size perforation 3 x 33 x 32
From 280 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 320 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M. 40 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name
Contractor
Address
Contractor

Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L. Hack
By driller performing actual drilling on site or contractor
Date 5-6-94

MAY 11 1994 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627