WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45036
Permit No.
Basin 105

NOTICE OF INTENT NO. 24935

1. OWNER WESTWIND'S CONST.
MAILING ADDRESS GARDNERVILLE, NV
ADDRESS AT WELL LOCATION 1842 BORDA GARDNERVILLE

2. LOCATION SW ¼ NW ¼ Sec. 36 T. 13 N S R. 20 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) Parcel No. 23-472-17 Subdivision Name WILDFLOWER

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	52	52
CEMENTED GRAVEL		52	65	13
SANDY CLAY		65	71	6
CEMENTED GRAVEL		71	98	27
SANDY CLAY		98	116	18
CEMENTED GRAVEL		116	131	15
CLAY & SANDY CLAY		131	272	141
CEMENTED SAND	✓	272	285	13
SANDY CLAY w/GRAVEL		285	289	4
FRACTURED BASALT	✓	289	311	22
SANDY CLAY w/GRAVEL		311	320	9

Date started 6-2, 1994
Date completed 6-10, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	25+	—	4

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	320 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	0	320

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 x 3/32
From 270 feet to 310 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 320 feet

9. WATER LEVEL
Static water level 160 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD. (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
Signed Pat J. Mar (By driller performing actual drilling on site or contractor)
Date 6-10-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627