

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26561

1. OWNER DENNIS LONG ADDRESS AT WELL LOCATION 1489 WILD IRIS GARDNERVILLE  
 MAILING ADDRESS EAGLE RIVER, ALASKA

2. LOCATION NW 1/4 SE 1/4 Sec. 36 T. 13 N. R. 20 E DOUGLAS County  
 PERMIT NO. 23-473-10 Subdivision Name WILDFLOWER  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	54	54
CEMENTED GRAVEL		54	114	60
SANDY CLAY		114	122	8
CEMENTED GRAVEL		122	136	14
SANDY CLAY + CLAY		136	291	155
SANDY CLAY w/GRAVEL		291	296	5
CEMENTED GRAVEL		296	314	18
SANDY CLAY w/GRAVEL		314	315	1

194 JUL -6 AM 11:21  
 STATE ENGINEERS

8. WELL CONSTRUCTION  
 Depth Drilled 315 Feet Depth Cased 315 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 315 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>315</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 x 3/32  
 From 295 feet to 315 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 315 feet

9. WATER LEVEL  
 Static water level 152 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

Date started 6-13, 1994  
 Date completed 6-22, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>4</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD Contractor  
FALLON, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726

Signed Paul J. Mooney  
 By driller performing actual drilling on site or contractor  
 Date 6-22-94