WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 45043
Permit No.
Basin 105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 25333

1. OWNER
MAILING ADDRESS Shiela Plunton 3423 Bernese crt CC NV
ADDRESS AT WELL LOCATION 3423 Bernese crt CC NV 89705

2. LOCATION SE ¼ SW ¼ Sec. 11 T. 14 N/S R. 19 E. Douglas County
PERMIT NO. (Issued by Water Resources) 15-094-05 (Parcel No.) Alpine View Est. (Subdivision Name)

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☒ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Existing Well | | | | |
| 120' Dropped | | | | |
| 6" liner 105' Deeper to bottom | | | | |
| DG, SAND & ROCK | XX | 120 | 135 | |
| SAND | | 135 | 150 | |
| SANDSTONE | | 150 | 175 | |
| SAND | | 175 | 185 | |
| SANDSTONE | XXX | 185 | 225 | |

'94 MAY 17 A10:17
STATE ENGINEER'S OFFICE

Date started 3-7, 1994
Date completed 3-9, 1994

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| Blow/Air | 25+ | — | 2½ hrs. |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 7 7/8 inches Total depth 225 feet
Casing record
Weight per foot 15 lbs Thickness 188

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | 105 feet | 225 feet |
| 8 5/8 inches | 0 feet | 120 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☐ No ☒ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory cut
Size perforation 3/32 X 3"
From 105 feet to 125 feet
From 205 feet to 225 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 59 feet below land surface
Flow G.P.M. P.S.I.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Rawhack Drilling Inc (Contractor)
Address PO Box 1359 Minden NV (Contractor)
Nevada contractor's license number #021268
Nevada contractor's drillers number #1380
Nevada driller's license number #1495 (Actual Driller)
Signed Michael Allen (Contractor)
Date 3-9-94

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434