



Log No. 45044
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24700

1. OWNER Judson Hill General Improvement Dist ADDRESS AT WELL LOCATION 74610
 MAILING ADDRESS Carson Valley NV Four Hat Springs Rd
Carson Valley NV

2. LOCATION AB AD 1/4 AC AD 1/4 Sec 25 T 14 R 17 E Douglas County
 PERMIT NO. NO 739 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG North East Well

Material	Water Strata	From	To	Thick-ness
<u>Silty Sandy Gravel</u>	<u>No</u>	<u>0'</u>	<u>5'</u>	<u>5'</u>
<u>Silty Sand</u>	<u>No</u>	<u>5'</u>	<u>8'</u>	<u>3'</u>
<u>Silty Clay</u>	<u>Yes</u>	<u>8'</u>	<u>10'</u>	<u>2'</u>
<u>Sandy Gravel</u>	<u>Yes</u>	<u>10'</u>	<u>20'</u>	<u>10'</u>
<u>Clay</u>	<u>Yes</u>	<u>20'</u>	<u>23'</u>	<u>7'</u>

8. WELL CONSTRUCTION
 Depth Drilled 23 1/2 Feet Depth Cased 23 1/2 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 23 1/2 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>Sch. 40</u>	<u>PVC</u>	<u>0</u>	<u>23 1/2</u>

Perforations:
 Type perforation Factory Slot
 Size perforation .070 Inch

From _____ feet to _____ feet
 From 8 1/2 feet to 18 1/2 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 6 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 6 feet to 23 1/2 feet

9. WATER LEVEL
 Static water level 10.0 feet feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Anderson Drilling Contractor
 Address 1635 Belford Rd. Contractor
RENO NV, 89509

Nevada contractor's license number issued by the State Contractor's Board 34525
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1667

Signed John Anderson
 By driller performing actual drilling on site or contractor
 Date 6/11/94

Date started 1-5 1994
 Date completed 1-5 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		<u>N/A</u>