

OFFICE USE ONLY
 Log No. **45047**
 Permit No. _____
 Basin **105**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **28944**

1. OWNER Cole Smith ADDRESS AT WELL LOCATION 1582 Saratoga ct
 MAILING ADDRESS PO 2410 Minden NV 89423 Minden NV
 2. LOCATION NW 1/4 NW 1/4 Sec. 14 T. 14 N/S R. 20 E Douglas County
 PERMIT NO. 21-153-38 High Rise Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	10	
SAND & GRAVEL (ROCK)		10	25	
SAND		25	35	
SAND & GRAVEL (ROCK)		35	70	
SAND		70	120	
SAND & SILTS	X	120	150	
SAND & SMALL ROCK	X	150	180	
ROCK	XX	180	185	
SANDS, SILTS, SM. ROCK	XX	185	230	

'94 JUL 13 AMT 415
 STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 230 Feet Depth Cased 230 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet 230 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12 SPS</u>	<u>.188</u>	<u>0</u>	<u>230</u>

Perforations:
 Type perforation Factory Perf
 Size perforation 3" x 5/2"
 From 230 feet to 210 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 230 feet to 50 feet

9. WATER LEVEL
 Static water level 145 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Kauchak Drilling Inc. Contractor
 Address PO Box 1359 Minden NV Contractor
 Nevada contractor's license number issued by the State Contractor's Board #021268
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #7495
 Signed Michael Allen
 By driller performing actual drilling on site or contractor
 Date 6-7-94

Date started 6-2, 1994
 Date completed 6-7, 1994

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>30F</u>	<u>-</u>	<u>3 hrs.</u>