

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 45051  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25945

1. OWNER Dirk Jansen ADDRESS AT WELL LOCATION 1595 Lindsay Ln. Minden NV  
 MAILING ADDRESS 1275 Downs Minden NV 89423  
 2. LOCATION NE 1/4 SE 1/4 Sec 27 T 14 N/S R 20 E Douglas County  
 PERMIT NO. 21-140-90 Parcel No. \_\_\_\_\_ Subdivision Name High Point

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	35	
SAND & SM. ROCK		35	75	
SAND		75	90	
SAND SM. ROCK		90	105	
SAND		105	190	
SAND & SILT	X	190	245	
CLAY & SAND	X	245	270	
SAND	X	270	300	
SAND CLAY & GRAVEL	X	300	315	
CLAY & SAND	X	315	340	

DATE: 94 JUL 13 AM 145  
 STATE: NEVADA

8. WELL CONSTRUCTION  
 Depth Drilled 340 Feet Depth Cased 340 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 Inches To 0 Feet  
 From 0 Feet To 340 Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 9/8</u>	<u>12.5 lbs</u>	<u>.188</u>	<u>0</u>	<u>340</u>

Perforations:  
 Type perforation Factory & hand-cut  
 Size perforation 3" X 5/16"  
 From 340 feet to 320 feet  
 From 300 feet to 280 feet  
 From 260 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 340 feet to 50 feet

9. WATER LEVEL  
 Static water level 180 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Kowchack Drilling Inc. Contractor  
 Address PO Box 1359 Minden NV Contractor  
 Nevada contractor's license number #021268 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #495  
 Signed Michael Allen  
 By driller performing actual drilling on site or contractor  
 Date 6-14-94

Date started 6-9, 1994  
 Date completed 6-14, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>40-50</u>	<u>-</u>	<u>3 hrs.</u>