

OFFICE USE ONLY  
 Log No. 45052  
 Permit No. \_\_\_\_\_  
 Basin. 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23631

1. OWNER Danny Whitmore ADDRESS AT WELL LOCATION 2820 Pamela Place  
 MAILING ADDRESS 2880 Pamela Place  
Monday Nevada  
 2. LOCATION SE 1/4 SE 1/4 Sec. 27 T. 14 N. R. 20 E. Douglas County  
 PERMIT NO. 21-153-15 Johnson Lake Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>sand</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>sandy clay with</u> <u>little black gravel</u> <u>&amp; sand.</u>		<u>8</u>	<u>179</u>	<u>171</u>
		<u>179</u>	<u>183</u>	<u>4</u>
<u>clay with some</u> <u>black gravel</u> <u>and occasional sand</u>		<u>183</u>	<u>238</u>	<u>55</u>
<u>Bot Rock</u> <u>fracture</u>	<input checked="" type="checkbox"/>	<u>238</u>	<u>246</u>	<u>8</u>

8. WELL CONSTRUCTION  
 Depth Drilled 246 Feet Depth Cased 246 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 246 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.93</u>	<u>.188</u>	<u>0</u>	<u>246</u>

Perforations:  
 Type perforation mill lots  
 Size perforation 1/2 x 2 1/4  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 180 feet to 200 feet  
 From 220 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
50  Seat Cement  
 Depth of Seal \_\_\_\_\_  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 246 feet

9. WATER LEVEL  
 Static water level 120' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality UNKNOWN

Date started 3-30 1994  
 Date completed 4-5- 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20 to 40 GPM</u>	<u>5 PM</u>	<u>2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name DASIS Drilling ELL Contractor  
 Address P.O. Box 21421 Contractor  
CARSON CITY NEVADA  
 Nevada contractor's license number issued by the State Contractor's Board 0023129  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1386  
 Signed T. H. Haggard  
 By driller performing actual drilling on site or contractor  
 Date 4-5-94