

OFFICE USE ONLY
Log No. 45058
Permit No. _____
Basin B-105

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 20839

PRINT OR TYPE ONLY

CDA

1. OWNER Dirk Jansee ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 1275 Downs 1576 Gloria Way
Minden, NV 89423 Minden, NV 89423
2. LOCATION SE 1/4 SW 1/4 Sec. 27 T. 14 N. S. R. 20 E. Douglas County
PERMIT NO. 21-140-68 Parcel No. _____ Subdivision Name High Point

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	45	
Sand + Gravel		45	80	
Sand		80	141	
Sand + Gravel		141	175	
clay		175	189	
Sand		189	245	
Sand + clay		245	305	
Sand, clay + Gravel		305	320	

'93 MAR 12 AIO 27
STATE ENGINEERS OF NV

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 320 feet
Casing record 6 5/8 x 188
Weight per foot _____ Thickness 188
Diameter From To
6 inches 0 feet 320 feet
Surface seal: Yes No Type Cement
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 50 feet to 320 feet
Perforations:
Type perforation factory
Size perforation 3 x 5/32
From 300 feet to 320 feet

Date started 2/19, 1993
Date completed 2/24, 1993

9. WATER LEVEL
Static water level 160 feet below land surface
Flow +20 G.P.M. _____ P.S.I.
Water temperature cold °F Quality N/A

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Bailer</u>	<u>+20 GPM</u>		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Kowchack Drilling Inc. Contractor
Address Rt # 3 2668 Fuller, Minden, NV 89423 Contractor
Nevada contractor's license number issued by the State Contractor's Board 021268
Nevada contractor's driller's number issued by the Division of Water Resources 1380
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1380
Signed [Signature] By driller performing actual drilling on site or contractor
Date 3/3/93

BAILER TEST
G.P.M. 420 Draw down NO feet 4 hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours