

OFFICE USE ONLY
 Log No. 45054
 Permit No. 105
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24934

1. OWNER TIM TOTALO ADDRESS AT WELL LOCATION STEFFANIE WAY
 MAILING ADDRESS ZEPHYR COVE, NV MINDEN, NV

2. LOCATION SE 1/4 SW 1/4 Sec. 29 T. 14 N. S. R. 20 E DOUGLAS County
 PERMIT NO. 21-290-51 JOHNSON LANE Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	14	14
course sand w/ sandy clay		14	24	10
Sandy clay / gravel		24	35	11
Sandy clay		35	57	22
gravel w/ sandy clay		57	70	13
Sandy clay		70	76	6
Sandy clay w/ coarse sand		76	85	9
large gravel w/ sandy clay	add	85	119	34
Sandy clay		119	130	11
Sandy clay / gravel		130	140	10

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 140
10 5/8 Inches Feet 140 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>6</u>	<u>140</u>

Perforations:
 Type perforation Factory slotted / T.C.
 Size perforation 3 x 3/32
 From TC 120 feet to 140 feet
 From factory 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 140 feet

Date started 6-7, 1994
 Date completed 6-8, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25+</u>		<u>1</u>

9. WATER LEVEL
 Static water level 10 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed Jerald W. Blinnell
 By driller performing actual drilling on site or contractor
 Date 6-8-94